

Assessment Results Exceedance Table

Of the 43 samples collected from Buildings A, B, D and E at Pines Bridge Campus, 1 (2.3%) had lead concentrations that exceeded 15 ppb. The table below details the sample location and the laboratory results.

Pines Bridge School				
Date	Sample ID	Floor	Location	Lead Level (ppb)
06/09/16	BLDG C-09A	1 st	DF – Room 126 (Engineering)	57.0

DF = Drinking Fountain

Assessment Results Exceedance Table

Of the 19 samples collected from Building B at Pines Bridge Campus as well Madden Campus Buildings (10.5%) had lead concentrations that exceeded 15 ppb. The table below details the sample location and the laboratory results.

Pines Bridge School				
Date	Sample ID	Floor	Location	Lead Level (ppb)
08/02/16	MAD-01A	1 st	S – Conference Barn Kitchenette	36.2
08/02/16	MAD-02A	Lower	S – Nature Center Slop Sink	91.2

S = Sink

Assessment Results Exceedance Table

Of the 6 samples collected from main Building at the Madden Campus (100%) had lead concentrations that exceeded 15 ppb. The table below details the sample location and the laboratory results.

PNW BOCES Madden Campus				
Date	Sample ID	Floor	Location	Lead Level (ppb)
09/15/16	MADD-01	1st	Sink from Left Bathroom near Kitchen	43.6
09/15/16	MADD-02	1st	Sink from Right Bathroom near Kitchen	39.0
09/15/16	MADD-03	1st	Sink from Bathroom adjacent to Office	39.8
09/15/16	MADD-04	Lower	Sink from Bathroom in Nature Center	38.5
09/15/16	MADD-05	Lower	Sink in Nature Center	70.6
09/15/16	MADD-06	Lower	Sink from Bathroom in Water Room	56.1



Assessment Results Exceedance Table

Of the 71 samples collected from Buildings A, B, D and E at Pines Bridge Campus, 7 (9.9%) had lead concentrations that exceeded 15 ppb. The table below details the sample locations and the laboratory results.

Pines Bridge School				
Date	Sample ID	Floor	Location	Lead Level (ppb)
10/19/16	BLDG B-09	1 st	Sink (#1) in Room 230 (the far left sink going L→R)	21.1
10/19/16	BLDG B-17	1 st	Sink in Room 225, Student Bathroom (#1 going L→R)	17.0
10/19/16	BLDG B-18	1 st	Sink in Room 225, Student Bathroom (#2 going L→R)	32.7
10/19/16	BLDG B-19	1 st	Sink in Room 225, Student Bathroom (#3 going L→R)	18.4
10/19/16	BLDG B-20	1 st	Sink in Room 225, Student Bathroom (#4 going L→R)	31.5
10/19/16	BLDG B-21	1 st	Sink in Room 225, Student Bathroom (#5 going L→R)	185
10/19/16	BLDG D-07	1 st	Sink (#1) in Room 110 (the far left sink going L→R)	20.9



Assessment Results Exceedance Table

Of the 86 samples collected Building C at Pines Bridge Campus, 3 (3.5%) had lead concentrations that exceeded 15 ppb. The table below details the sample locations and the laboratory results.

Pines Bridge Campus				
Date	Sample ID	Floor	Location	Lead Level (ppb)
10/26/16	BLDG C-51	Lower	Sink in Room 116 (Slop Sink, Left)	26.4
10/26/16	BLDG C-52	Lower	Sink in Room 116 (Slop Sink, Right)	27.2
10/26/16	BLDG C-71	Lower	Sink in New Visions (Right)	22.1



Assessment Results Exceedance Table

Of the 38 first draw samples analyzed from Fox Meadow Campus, 4 (10.5%) had lead concentrations that exceeded 15 ppb. The table below details the sample locations and the laboratory results.

Fox Meadow Campus				
Date	Sample ID	Floor	Location	Lead Level (ppb)
11/2/16	FM B1-1A	1 st	Sink #1 in Building 1 Bathroom	22.5
11/2/16	FM B9-6A	1 st	Sink in Lab Prep & Storage Room Bldg 9	15.3
11/2/16	FM B8-4A	1 st	Sink in Women's Bathroom Bldg 8 (Right)	38.2
11/2/16	FM B7-2A	1 st	Sink #1 in Building 7 Bulk Storage Room	1850